



BATTERY DISCHARGE REPORT

Customer Name	GJ Maskin AB
Operator Name	
Battery identification	417446130050
Cell Voltage (V)	48
Cell Number	24
Battery Capacity (Ah)	750
DISCHARGE SETTING	
Current (A)	140,00
Minimum battery voltage (V)	40,80
Maximum time (m)	UNLIMITED
Serial number	152544
Sampling Time (s)	180
Firmware Revision	140
TEST RESULTS	
Starting time	2023-08-31 07:03:04
Discharged capacity (Ah)	742,80
Total time of discharge	5h16'
Initial battery voltage (V)	54,96
Final battery voltage (V)	40,79
Ending condition	END_CYCLE_VBATT_LOW



Report Notes